

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number	Page of Pages	
				1	2
2. Amendment/Modification Number		3. Effective Date	4. Requisition/Purchase Request No.		5. Solicitation Caption
GF-2018-B-0051-004		August 23, 2018			UDC Building 42 ETQL and Labs 215 & 216
6. Issued By: University of the District of Columbia OSS&P Capital Procurement Division 4200 Connecticut Avenue, NW, Room C/04 Building 39, Room 200C Washington, DC 20008		Code	7. Administered By (If other than line 6) University of the District of Columbia OSS&P Capital Procurement Division 4200 Connecticut Avenue, NW Building 39, Room 200C Washington, DC 20008		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			<input checked="" type="checkbox"/>	9A. Amendment of Solicitation No.	
				GF-2018-B-0051	
				9B. Dated (See Item 11) June 22, 2018	
				10A. Modification of Contract/Order No.	
				10B. Dated (See Item 13)	
Code	Facility				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>5</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
A. This change order is issued pursuant to: (Specify Authority)					
The changes set forth in Item 14 are made in the contract/order no. in item 10A.					
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.					
C. This supplemental agreement is entered into pursuant to authority of:					
D. Other (Specify type of modification and authority)					
<b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>5</u> copy to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)					
Announcement No. GF-2018-B-0051, UDC Building 42 ETQL and Labs 215 & 216 at the University of the District of Columbia is hereby amended as follows:					
1) Additional Question & Answer (Attached)					
2) The closing date for submission of bids is extended from Tuesday, August 28, 2018 to Thursday, August 30, 2018 to 2:00PM.					
3) All other Terms and Conditions remain the same.					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer		
			Eddie Whitaker		
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia		16C. Date Signed
			Eddie Whitaker		8/24/18
(Signature of person authorized to sign)			(Signature of Contracting Officer)		

## Questions & Responses

1	<i>The drawings show a dimension between horizontal tubes of 2'11" as the max. At this point we can handle up to 50psf. If the requirement is more, additional tubes have to be installed.</i>	Structural Engineer's response is: "If the panel can withstand 50 psf that would be more than sufficient."
---	--	--