

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. Contract Number	Page of Pages	
2. Amendment/Modification Number		3. Effective Date	4. Requisition/Purchase Request No.	1	3
GF-2021-B-0021-005		See item 16C	5. Solicitation Caption Academic Commons Relocation of LRD & CAL		
6. Issued By: University of the District of Columbia Office of Contracting & Procurement 4200 Connecticut Avenue, NW Building 39 Suite 200C Washington, DC 20008		Code	7. Administered By (If other than line 6) University of the District of Columbia Office of Contracting & Procurement 4200 Connecticut Avenue, NW Building 39 Suite 200C Washington, DC 20008		
8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)			(X)	9A. Amendment of Solicitation No. GF-2021-B-0021	
				9B. Dated (See Item 11) July 5, 2021	
				10A. Modification of Contract/Order No.	
				10B. Dated (See Item 13)	
Code	Facility				
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS					
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of bids <input checked="" type="checkbox"/> is extended. <input type="checkbox"/> is not extended. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.					
12. Accounting and Appropriation Data (If Required)					
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14					
A. This change order is issued pursuant to: (Specify Authority)					
The changes set forth in Item 14 are made in the contract/order no. in item 10A.					
B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.					
C. This supplemental agreement is entered into pursuant to authority of:					
D. Other (Specify type of modification and authority)					
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copy to the issuing office.					
14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)					
Invitation for Bid No. GF-2021-B-0021 for Academic Commons - Relocation of LRD & CAL amended as follows: 1. Additional Questions & Answers (attached) 2. Deadline for Submission of Bid: Monday, August 23, 2021, by 2:00 PM. Call in (audio only) +1 206-413 8593 United States, Seattle Phone Conference ID: 578 794 203#					
Submission of proposals should be submitted via email to Michiko Gadson at mgadson@udc.edu.					
ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED					
Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect					
15A. Name and Title of Signer (Type or print)			16A. Name of Contracting Officer Eddie Whitaker		
15B. Name of Contractor		15C. Date Signed	16B. District of Columbia		16C. Date Signed
<div style="text-align: center;"> (Signature of person authorized to sign) </div>		<div style="text-align: center;"> (Signature of Contracting Officer) </div>	<div style="text-align: center;"> (Signature of Contracting Officer) </div>		8/16/2021

Attachment A

Additional Questions & Answers

Questions & Answers

GF-2021-B-0021, Academic Commons - Relocation of LRD & CAL

8/16/21

8/16/21

- 21 What type of frame is #T210B? It's listed as a Type 1, which isn't defined. The floor plan references elevation A300/L1 which is a giant storefront/glass elevation but the door is a type B (and a type B door is not what is shown on the elevation)? Type 1 frame is FA. Door to match Study Room L230/232
- 22 What type of frame is #T205? It's listed as a type FA on the door schedule but floor plan shows SF2? Is this a storefront frame with a wood type B door? Yes, it is a storefront frame with a wood door , type B
- 23 Frame #'s L211, C219b, C219a, C221 are listed as type 1 on the door schedule but type 1 isn't defined. Looking at the floor plan these appear to be type FA frames? Type 1 frame is FA.
- 24 Door C211a and T210B say "N/A" for the hardware? C211a shall be Set 2 and T210B to be Set 8.
- 25 Door #205, T209D, T209B, T209C, T209A have no hardware listed? Door 205 does not exist. T209A to D shall by Set 8.
- 26 Door C211 and C212 appear to be storefront doors but are listed as wood type D doors. There's no frame type listed but the floor plan shows SF1. Also the hardware is set 8, which is for a storefront door. What type of doors are these supposed to be? C211 and C212 are wood doors in storefront frame as shown in elevation c1/a300
- 27 The following hardware sets/doors are assigned to be wood doors but have storefront hardware assigned to them. The hardware on these doors are confusing. —
- Set 8 #C211, C212, L237, T205, T215 C211/C212 HM /glass door in storefront. Door L237 is in wall partition. T205 and T215 are storefront system. Card reader with door pull/closer
- Set 12 #201, C219a, C219b, C221, C225, L100, L204, L238 201 is SF with wood door, C219a, b, C221 and C225 are wood doors in partition. L100 is existing to remain, L204 is SF with wood door. L238 is closet (set 8)
- Set 12A #C220 Type B door in Frame FB - touchless hardware
- Set 14 #203, C207, C209 Toilet door hardware- touchless.
- 28 Pairs of doors with a type FB frame (sidelite frame) indicated on the door schedule i.e. C202A, C204A, C206A, 206, T204A should be type FA (3 sided frame) according to the floor plan. Frame type shall be FA